



City of
Burnaby

City of Burnaby Fire Department
604-294-7195
fire@burnaby.ca

All upgrades, improvements, and renovations will require a permit be issued the Building Department at Burnaby City Hall.

Before purchase or rent of a building, it may be important to perform:

1. A record search
2. An on-site inspection

to ensure that the building adheres to all applicable bylaws and regulations.

These services require the current owner's approval and are available upon request. Sprinklered buildings will have special consideration, and plan approval is imperative.

Commercial Cooking Extinguishing System Upgrade

Previous standards for commercial cooking extinguishing systems were established approximately 30 years ago. Since then, changes in cooking equipment and cooking methods have created the potential for fire hazards that were not considered when the previous standards were developed.

Because of this, existing extinguishing systems tested to the previous standards may not be capable of controlling and extinguishing fire occurring in current commercial cooking operations.

The Office of the Fire Commissioner now requires extinguishing fire systems for commercial cooking equipment to be upgraded to meet UL 300 - ULC 1254.6 standards.

Extinguishing systems that have been upgraded to meet the new ULC 1254.6 standards must be labeled for inspection by the Burnaby Fire Department.